

Trane Thailand e-Magazine





02 HEAT PUMP เศรื่องทำน้ำร้อน







อีกไม่ที่วันก็จะเข้าสู่ปีใหม่ พุทธศักราช ๒๕๕๙ ต้อนรับ "ปีวอก" กันอย่างสดใส...."ลิง" ถือเป็น สัญลักษณ์ของความฉลาดปราดเปรื่อง คล่องแคล่วว่องไว และร่าเริง สนุกสนาน พมขอให้เป็น ปีที่ทุกท่านสามารถคิดอ่าน วางแพนธุรกิจการงานได้อย่างปราดเปรื่อง พลิกแพลงแก้ไขบัญหาได้อย่างคล่องแคล่ว ด้วยสติบัญญาที่เฉลียวฉลาด และจิตใจที่สดชื่นแจ่มใส พมเชื่อว่าจิตใจที่ เข้มแข็ง และเชื่อมั่น จะสามารถนำพาให้ทุกท่านพบกับสิ่งดีๆ ตามที่ปรารถนาได้ครับ

ในโอกาสนี้ พมขอเป็นตัวแทนของ 'เทรน' เพื่อกล่าว 'ขอบคุณ' ลูกค้าทุกท่านที่ให้ความเชื่อมั่น ในพลิตภัณฑ์ และบริการต่างๆ ของเรา โดยในช่วงไตรมาสสุดท้ายของปีนี้ มีการสั่งซื้อต่อเนื่อง จากโครงการใหม่ของบริษัทชั้นนำระดับประเทศ โดยหนึ่งในเหตุพลสำคัญ คือ 'เทรน' ช่วยให้ การใช้พลังงานมีประสิทธิภาพสูงสุด อย่างที่ไม่มีใครทำได้ในเวลานี้ ไม่ว่าจะเป็นโครงการใหญ่ ระดับโลก ที่จะเป็นแลนด์มาร์คแห่งใหม่ริมพั่งแม่น้ำเจ้าพระยา ที่เลือกใช้หิลเลอร์ 'เทรน' ในส่วน ของหางสรรพสินค้าและสำนักงาน โดยใช้พลังงานเพียง 0.575 กิโลวัตต์ต่อตัน, หางสรรพ สินค้าชื่อดัง ย่านปทุมวันที่มีการปรับปรุงพื้นที่ให้บริการอย่างเต็มรูปแบบเป็นครั้งแรกในรอบ เกือบ 20 ปี เปลี่ยนชิลเลอร์ทดแทนชิลเลอร์เดิมบางส่วน เพื่อประสิทธิภาพพลังงานที่ดีขึ้น คือ 0.54 กิโลวัตต์ต่อตัน, โรงงานอุตสาหกรรมพลิตฮาร์ดดิสขนาดใหญ่ระดับโลก ที่สร้างฐานการ พลิตใหม่ที่โคราช เลือกใช้ 'เทรน' ทั้งในส่วนสำนักงาน และส่วนการพลิต ด้วยใช้พลังงานเพียง 0.552 กิโลวัตต์ต่อตัน

นอกจากนี้ยังมีโครงการ High Efficiency Chiller Plant Guarantee เพื่อปรับปรุงการใช้ พลังงานของห้างสรรพสินค้าขนาดใหญ่ที่สุดในย่านบางนา โดยเทรนได้ทำการประเมินการใช้ พลังงานจริงของโครงการ และเสนอแพนปรับปรุงพร้อมการรับประกัน

โดยมีการการันตีค่าการใช้พลังงานที่ 0.66 กิโลวัตต์ต่อตัน ในระยะเวลา 5 ปี หากมีการใช้งานจริงเกินกว่าที่รับประกันไว้ เทรนจะชดเชย ค่าไฟฟ้าส่วนต่างให้แก่โครงการ ซึ่งการที่ 'เทรน' กล้าให้การ รับประกันแก่ลูกค้าในลักษณะนี้ เพราะเราเชื่อมั่นในพลิตภัณฑ์ และความเชี่ยวชาญด้านระบบปรับอากาศอย่างแท้จริง

และสำหรับ e-Magazine ในฉบับต้อนรับปีใหม่นี้ เรายังคง ส่งต่อเนื้อหาสาระดีๆ ให้แก่ทุกท่าน ซึ่งสามารถติดตามอ่าน ได้ในฉบับครับ หากมีข้อแนะนำ หรือข้อสงสัยเกี่ยวกับ 'เทรน' สามารถส่งมาได้ที่ info@tranethailand.com ครับ

พัลลภ เตษ:สุวรรณ์ Thailand Country General Manager



info@tranethailand.com







Trane Care Services

HEAT PUMP เศรื่องท่าน้ำร้อน

Heat Pump คือ เครื่องทำน้ำร้อนที่ใช้หลักการทำงานแบบเดียวกับ ระบบปรับอากาศโดยทั่วไป เช่น เครื่องปรับอากาศแบบแยกส่วน จะมีลักษณะเช่นเดียวกับระบบการทำความเย็นแบบอัดไอ (ดังรูป A) เพียงแต่ heat pump จะเลือกใช้ประโยชน์จากทางด้านความร้อน เป็นหลัก คือการนำเอาความร้อนที่ดูดซับมาจากด้าน evaporator ถ่ายเทไปยังด้านรับความร้อน (condenser) แบบต่อเนื่อง ความ ร้อนนั้นก็จะสะสมจนมีอุณหภูมิที่สูงขึ้น แล้วความร้อนนั้นจะถูกถ่าย เทต่อไปยังน้ำทำให้เราได้น้ำร้อนตามอุณหภูมิที่ต้องการ

การถ่ายเทความร้อนไปสู่น้ำ ทำให้เราได้น้ำร้อน และยังสามารถควบ คุมอุณหภูมิความร้อนได้ ดังนั้น Heat pump จึงได้ประโยชน์จาก ทั้งด้านความร้อนและความเย็น ทำให้เป็นอุปกรณ์ที่มีประสิทธิภาพ สูง และช่วยประหยัดพลังงานเป็นอย่างมาก

Condenser QC

Water Supply Inlet

Evaporator

Compressor

Heat Energy Input of Other Medium

OA

Liquid Preserved Tank

Filter

Expansion Valve

เครื่องทำน้ำร้อน (Heat pump) ของเทรนที่มีประสิทธิภาพสูง และ เป็นที่นิยม ได้แก่ Trane Air-Water Heat Pump Central Type ซึ่งมีคุณสมบัติพิเศษดังนี้

- สามารถทำอุณหภูมิน้ำร้อนได้สูงสุด 70 °C
- ประหยัดพลังงานไฟฟ้ากว่าการใช้ฮีตเตอร์ ถึง 4 เท่า
- ในส่วนของความเย็นทางด้านอีแวปปอเรเตอร์ สามารถนำไปใช้ ประโยชน์อื่นๆได้ เช่น นำไปใช้ร่วมกับระบบปรับอากาศหลัก

 Comparison with the daily cost of heating hot water for a 100-room hotel (Baht)



Diesel Oil Grade A LPG Electric Element Heat Pump

Range of HWHP Available for Central Heat Pump System Model: HPAT- 20, 30, 60, 72, 100



- 22 100 kW Heating Capacity
- Produces up to 69,000
 Litre/day
- High efficiency @ COP more than 4.3
- Heavy duty galvanised casing for all installation condition
- Compliance with UL standard



Spare Parts Updated

Energy Valve Abuls:nou Belimo CCV (Characterised Control Valve) Electromagnetic flow sensor Advance control options including Belimo Delta Manager Supply and return water temperature

Energy Valve คือ Pressure Independent Valve ที่ช่วยเพิ่ม ประสิทธิภาพการทำงานของ Water coil รวมถึงการจัดเก็บข้อ มูลการทำงานและปรับตั้งค่าการใช้งานโดยอุปกรณ์อิเล็กทรอนิค จากการใช้ Electronic Pressure Independent Valve (EPIV) platform ตรวจวัดค่าการใช้พลังงานของคอยล์โดย electromagnetic flow sensor, water supply และ return temperature sensors

sensors, for energy management


communication


BACnet MS/TP or BACnet IP network

นอกจากนี้ Energy Valve ยังได้นำ Belimo Delta T Manager Algorithm ซึ่งเป็นส่วนที่ช่วยตรวจจับและปรับสมดุลการใช้ พลังงานของคอยล์ โดยการรับส่งข้อมูลไปที่ DDC system พาน BACnet Protocolทั้งนี้ข้อมูลประสิทธิภาพการทำงาน ทั้งหมดของคอยล์ที่จัดเก็บไว้จากการทำงานของ Actuator เช่น ความแตกต่างของอุณหภูมิ และปริมาณการใช้พลังงาน จะถูกนำ มาเก็บรวบรวมเป็นฐานข้อมูลรูปแบบการทำงานและการใช้งาน จากนั้นจะถูกส่งไปที่ BAS โดย data network

Energy Valve นี้ได้ถูกนำไปใช้กับห้องสมุด Hayden Library ที่ The Massachusettes Institue of Technology (MIT) มหาวิทยาลัยชั้นนำของโลก ซึ่งประสบปัญหาการใช้พลังงานสิ้น เปลืองเกินความจำเป็น ถึง 1.5 ล้านดอลลาร์สหรัฐต่อปี ซึ่งมี สาเหตุหลักมาจากระบบปรับอากาศ (chillers, pumps, และ cooling tower fans) ซึ่งปัญหาที่เกิดขึ้นนั้นมาจากหลายสาเหตุ อาทิ การติดตั้งอุปกรณ์ระบบปรับอากาศที่ไม่เหมาะสมกับสภาวะ การใช้งาน, ขนาดของคอนโทรลวาล์วใหญ่เกินไป และอื่นๆ ซึ่งส่ง พลให้ความสามารถในการแลกเปลี่ยนความร้อนในระบบทำงานได้ ไม่เต็มประสิทธิภาพ และก่อให้เกิดภาระการทำงานต่อปั๊มที่ต้อง ทำงานหนักเกินความจำเป็น

แต่ปัญหาเหล่านี้ได้รับการแก้ไขเมื่อได้ติดตั้ง Energy Valve ให้ห้องสมุดแห่งนี้ ด้วยระบบ ควบคุมอิเล็กทรอนิกทั้งหมด ช่วยจัดเก็บข้อมูลการทำงานและการใช้พลังงานที่เหมาะสม ให้แก่ระบบ ซึ่งจะเห็นได้ว่าการจัดการระบบที่ดีสามารถช่วยลดการใช้พลังงานที่เกินจำเป็น ช่วยยืดอายุการใช้งานของอุปกรณ์ต่างๆ และที่สำคัญ คือช่วยประหยัดค่าไฟล่วนเกินที่ ต้องจายถึง 1.5 ล้านดอลล่าห์สหรัฐต่อปีได้





Features/ Benefits

Power and energy monitoring function:

มี temperature sensors 2 ตัว สำหรับ supply and return lines of the consumer (heat and cold registration) และปริมาณน้ำที่ใช่ในระบบสามารถตรวจวัดได้จาก flow sensor ที่รวมอยู่ในระบบช่วยให้ควบคุมการจัดการการใช้พลังงานทำได้ด้วยระบบ ประมวลพลอิเล็กทรอนิกตลอดเวลา

Data recording:

ข้อมูลสำหรับการจัดการพลังงานทั้งระบบสามารถจัดเก็บได้นานถึง 13 เดือน และยัง สามารถดาวนโหลดข้อมูลพ่าน web browser จากภายนอกได้อีกด้วย

Manual override:

มีปุ่มกดรองรับการใช้งานแบบ manual

High functional reliability:

Actuator มีระบบป้องกันการทำงาน overload ในตัวเอง

Home position:


Actuator ขยับไปที่ตำแหน่ง home เมื่อมีการจ่ายกระแสไฟฟ้าเข้าครั้งแรก จากนั้นจึง ขยับไปสู่ตำแหน่งที่ตั้งค่าไว้จากค่าสัญญาณไฟฟ้าที่กำหนด


Parameterisation:


กำหนดค่าพารามิเตอร์ได้ง่ายและรวดเร็วพ่าน integrated web server

Recommended installation positions:

สามารถติดตั้ง Actuator ได้ทั้งแนวตั้งและแนวนอน









Engineers Newsletter

volume 44-3

Part 3 (end)

Dual-Temperature Chiller Plants

Plant with Three or More Chillers

When the plant is designed to include three or more chillers, the most efficient configuration is likely to use the dedicatedchillers approach with interconnecting pipes and shutoff valves to provide redundancy.

In this configuration (Figure 9), one chiller is selected and optimized to supply 57°F water to the terminal units, while a separate chiller is selected and optimized to supply 40°F water to the dehuminidifying coils. The third chiller is then selected so that it os capable of providing either 57°F or 40°F water, in the event that one of the other two chillers is in need of service:

- If the "warm-water" chiller (chiller 1) fails, valve V-1 is closed, valves V-3 and V-4 are opened, and chiller 3 is operated to supply 57°F water to the terminal units.
- If the "cold-water" chiller (chiller 2) fails, valve V-2 is closed, valves V-5 and V-6 are opened, and chiller 3 is operated to supply 40°F water to the dehumidifying coils.


Even if the chiller plant was originally conceived to include only two chillers, it may be desirable to design it for three chillers instead, so that the plant provides added redundancy in the event of a chiller failure. This would allow the "warm-water" chiller to be optimized to supply 57°F water, without sacrificing efficiency by having to select it to capable of making 40°F in an emergency (as would be required in a plant with only two chillers)

Incorporating a Water Economizer

Most buildings that include sensible-only terminal units use a dedicated outdoor air (OA) system for ventilation, so conventional air economizing is usually not possible. Therefore, a water economizer may be used to provide "free" cooling during mild weather. This can be particularly valuable for systems that use chilled-water terminal units for space cooling, since interior zones may require a supply of water for cooling, even when it's cold outside. In this case, water economizers can allow the chillers to be turned off during the colder months of the year.

Water economizing with water cooled chillers. If water-cooled chillers are used, a water economized is typically provided using either 1) a separate plat-and-frame heat wxchanger, or 2) by configuring one of the water chillers as a "free-cooling" centrifugal chiller (i.e., a themosiphon).

Figure 9. Dual-temperature plant with third chiller for redundancy



- * included if variable-flow chiller pumps are used
- ** some systems configure one chiller as a "free-cooling" chiller, while others include a separate plate-and-frame heat exchanger for water economizing

When a plate-and-fram heat exchanger is used, cold water from the cooling tower passes through one side of the heat exchanger, which cools the chilled water flowing through the other side. In most applications, locating this heat exchanger to pre-cool the warm water returning from the terminal units provides the greatest benefit (see Figure 3-9). This location is where the chilled-water loop is warmest, so the water economizer is able to reduce the chiller load any time the cooling tower is able to produce water that is colder than about 61°F for this example (63°F return water minus a 2°F heat exchanger approch).

Some engineers express concern that, in this location, the water economizer can only reduce the cooling load from the terminal units, but not from the dehumidifying coils. In this example, for the water economizer to reduce the load from the dehumidifying coils, the cooling tower must be able to produce water that is colder than 54°F (56°F return water minus a 2°F approach). This would likely require the outdoor wet-bulb temperature to be below 47°F (assuming a 7°F cooling tower approach); meaning that the corresponding outdoor dew point would be no higher than 47°F (Figure 10).

That is, at conditions when the cooling tower is capable of producing water that is cold enough to reduce the load from the dehumidifying coils, the outdoor dew point is likely below the setpoint of the dedicated OA systems, so the dehumidifying coils would be off (Figure 10). Therefore, in most applications where sensible-only



terminal units are used, there is likely little or no load from the dehumidify coils when water economizing is available. (The exception is a system with many operating hours when it is hot and dry outside, such that the coils in the dedicated OA units still need to cool the outdoor air.)

In many applications, its may be more desirable to use a free-cooling chiller, which would avoid the added cost of the plate-and-frame heat exchanger and added maintenance required to clean it. In a centrifugal chiller, heat can be transferred inside the chiller via refrigerant migration without needing to operate the compressor (i.e., a thermosiphon).


When the temperature of the water entering the condenser (from the cooling tower) can be colder than the desired temperature leaving the evaporator, the compressor is turned off and values inside the chiller refrigeration circuit are opened. Refrigeration vapor from the evaporator migrates directly to the condenser, where the temperature is cooled and, thus, the refrigerant pressure is lower. After the refrigerant pressure is lower. After the refrigerant condenses, another opened valve allows the liquid refrigerant to flow, by gravity, back into the evaporator. This allows the refrigerant to circulate between the evaporator and condenser without needing to operate the compressor.

A free-cooling chiller may be able to produce up to 45 percent of its design capacity without compressor operation, particularly in systems that use warmer leaving-evaporator temperatures. Therefore, in a plant with dedicated chillers (Figures 8 or 9), configuring the "warm-water" chiller (chiller 1) for free cooling would provide the most benefit. Or in plant with chillers in series (Figure 4, 5 or 7), configuring the upstream chiller (chiller 1) for free cooling would provide the most benefit.

Water economizer with air-cooled chillers. If air-cooled chillers are used, a water economizer is typically provided using either 1) an air-to-water heat exchanger incorporated into the air-cooled chiller (typically mounted on the outside of the air-cooled condenser coils), or 2) a separete air-to-water heat exchanger ("dry cooler" or closed-circuit cooling tower).

The benefit of incorpoating the heat exchanger into the air-cooled chiller is that it usually comes factory-assembled with integrated controls. The drawback is that if the plant includes only one chiller, the water economizer is not able to provide any energy-saving benefit until is cold and dry enough outside that the dehumidifying coils are shut off and the chiller setpoint is reset up to 57°F.

Figure 10. Water economizing likely not useful for dehumidifying coils



Using a separate dry cooler, piped in to pre-cool the warm water returning from the terminal units (see Figure 2), typically results in more cooling energy savings since it can reduce the cooling load from the terminal units whenever the outdoor dry-bulb temperature is about 10°F cooler than the water returning from the terminal units (63°F-10°F = 53°F). Plus, the dry cooler fans only operate when water economizing occurs; whereas if the air-to-water heat exchanger is incorporated into the air-cooled chiller, the condenser fans have to overcome the added pressure drop of those coils any time the chiller is operating.

For a single-chiller plant that uses a glycol-isolation heat exchanger (see Figure 1), a separate dry cooler would likely be piped into the glycol side of the heat exchanger for freeze protection. This would likely result in less cooling energy savings than if it were piped in ther terminal units. But once it's dry enough outside that the dehumidifying coils are shut off, the chiller setpoint can be result up to 55°F (57°F supply water to terminal units minus a 2°F heat exchanger approach) and the water economizer more efficiently reduces the cooling load from the terminal units. In this case, incorporating the water economizer into the air-cooled chiller may be preferred, since there is less benefit frm using the separate dry cooler.

Summary

In systems that use sensible-only, chilled-water terminal units, a dual-temperature chiller plant that uses separate water chillers can efficiently provide different water temperatures for both space sensible cooling and dehumidification. Interconnecting pipes and valves can allow the same plant to provide redundant capacity if either of the chillers needs to be repaired, replaced, or serviced. Including more than two chillers allows for more optimal chiller selections and can provide efficient operation at low loads.

By John Murphy applications engineer, Trane. You can find this and prevoius issues of the Engineers Newsletter at www.trane.com/engineersnewsletter. To comment, send to ENL@trame.com



Trane Tips





วิธีทำ: นำกระดาษห่อของขวัญลายน่ารัก กระดาษสี หรือเทปที่มีลาย มาแปะไปบน เชือกเส้นเล็ก แล้วตัดให้เป็นรูปสามเหลี่ยม หรือเราจะตัดให้เป็นรูปสามเหลี่ยมก่อนค่อย แปะบนเชือกก็ได้





จากนั้น นำเชือกพร้อมรูปสามเหลี่ยมมา ประดับบนตัวการ์ดซึ่งเราตัดรอไว้ก่อนแล้ว หรือจะเป็นการ์ดสำเร็จก็แล้วแต่ความสะดวก

ส่งสุขด้วย การ์ดปิใหม่ ท่ามือ





ง่ายๆแค่นี้เราก็จะได้การ์ดที่ทำเองกับมือแล้ว ลองทำกันดูนะคะ ^^











ขอบคุณข้อมูลจาก pantip.com

เทรน (ประเทศไทย)

บริษัท แอร์โค จำกัด ชั้น 30-31 อาคารวานิช 2 เลขที่ 1126/2 ถนนเพชรบุรีตัดใหม่ แขวงมักกะสัน เขตราชเทวี กรุงเทพฯ 10400 โทร. 0 2704 9999, 0 2704 9797 www.tranethailand.com



info@tranethailand.com



facebook/TraneThailand